

The floor plan shows a building layout with several rooms and technical details:

- Top Section:** Two large rectangular rooms, likely storage or utility spaces.
- Left Wall:** A series of small, rectangular openings, possibly for ventilation or access.
- Central Area:**
  - HR1, HR2, HR3, HR4:** Stavející rozvaděč (Building distribution units) located along the top and bottom walls.
  - KS1, KS2:** Stavející kompenzační rozvaděč (Building compensation distribution units) located on the left side.
  - USM:** Stavející zdroj napájení (Building power source) located on the left side.
  - HR21:** Stavející rozvaděč (Building distribution unit) located in the center.
  - RSP1:** Stavející rozvaděč (Building distribution unit) located in the center.
- Bottom Section:**
  - MÍSTNOST ENERGOBLOKU:** A room with a floor area of 102,0 M<sup>2</sup>, ceramic floor, and a height of 4,750 M. It contains a "stavející zdroj napájení" (building power source).
  - SV. VÝŠKA: 3,700 M:** A note indicating the height of the building.
  - POTRUBÍ VODY PITNÉ DEMONTOVAT, ZASLEPIT:** A note indicating that the drinking water pipe should be removed and sealed.
  - VEDENO POD STROPEM:** A note indicating that the pipe is run under the roof.
  - UMYVADLO DEMONTOVAT:** A note indicating that the sink should be removed.
  - POTRUBÍ KANALIZACE SPLAŠKOVÉ DEMONTOVAT, ZASLEPIT:** A note indicating that the sewerage pipe should be removed and sealed.

[illegible]

**U** UMYVADLO DEMONTOVAT VČETNĚ VÝTOKOVÉ BATERIE, PŘIPOJOVACÍHO POTRUBÍ  
VODY PITNÉ A KANALIZACE SPLAŠKOVÉ DEMONTOVAT A ZASLEPIT

\_\_\_\_\_ VODA PITNÁ  
\_\_\_\_\_ KANALIZACE SPLAŠKOVÁ

ZPRACOVAL	Ing. Barbora Gajdušková <i>Gajdušková</i>	ZPRACOVATEL	GENERÁLNÍ PROJEKTANT  <b>EP ROŽNOV</b> člen ČEZ ESCO <b>EP Rožnov, a.s.</b> Boženy Němcové 1720 CZ 756 61 Rožnov pod Radhoštěm tel.: 571 664 111, fax: 571 664 400 e-mail: ep@eproznov.cz	
KONTROLOVAL	Ing. Radek Buchta <i>Radek</i>			
SCHVÁLIL (HIP)	Ing. Bohuslav Šulák <i>Šulák</i>			
INVESTOR	NsP Karviná Ráj, p.o.			
MÍSTO STAVBY	Orlová	ČÍSLO ZAKÁZKY	K21148016	
STAVBA <b>Instalace nového náhradního zdroje el. energie 650kVA v Nemocnici Orlová</b>				
OBJEKT	D.1 SO 01 Stavební úpravy objektu energobloku			
STAVEBNÍ/INŽENÝRSKÝ OBJEKT	D.1.4 TZB (Vytápění, ZTI)			
NÁZEV VÝKRESU	DATUM		MĚŘÍTKO	KOPIE
<b>Půdorys 1.NP-ZTI</b>	01/2022		<b>1 : 100</b>	
	POČET A4			
	STUPEŇ	OZNAČENÍ VÝKRESU		
	<b>DPS</b>	<b>21148U61-03</b>		